



Polar diagram

Cone diagram

UGR diagram

| Glare evaluation according to UGR | | | | | | | | | | | | | |
|--|------|---|------|------|------|------|--|------|------|------|------|------|------|
| ρ Ceiling | | 70 | 70 | 50 | 50 | 30 | 70 | 70 | 50 | 50 | 30 | | |
| ρ Walls | | 50 | 30 | 50 | 30 | 30 | 50 | 30 | 50 | 30 | 30 | | |
| ρ Floor | | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | 20 | | |
| Room size X Y | | Viewing direction at right angles to lamp axis | | | | | Viewing direction parallel to lamp axis | | | | | | |
| 2H | 2H | 22.9 | 24.2 | 23.2 | 24.4 | 24.6 | 25.3 | 26.5 | 25.6 | 26.7 | 27.0 | | |
| | | 3H | 22.8 | 23.9 | 23.1 | 24.2 | 24.4 | 26.6 | 27.7 | 26.9 | 27.9 | 28.2 | |
| | | 4H | 22.8 | 23.8 | 23.1 | 24.1 | 24.4 | 26.9 | 28.0 | 27.3 | 28.2 | 28.5 | |
| | | 6H | 22.7 | 23.7 | 23.1 | 24.0 | 24.3 | 27.1 | 28.0 | 27.4 | 28.3 | 28.6 | |
| | | 8H | 22.7 | 23.6 | 23.1 | 23.9 | 24.2 | 27.1 | 28.0 | 27.5 | 28.3 | 28.6 | |
| 4H | 12H | 22.7 | 23.5 | 23.0 | 23.8 | 24.2 | 27.1 | 27.9 | 27.4 | 28.2 | 28.6 | | |
| | | 2H | 23.5 | 24.5 | 23.8 | 24.8 | 25.0 | 25.5 | 26.6 | 25.9 | 26.8 | 27.1 | |
| | | | 3H | 23.4 | 24.2 | 23.7 | 24.6 | 24.9 | 26.9 | 27.8 | 27.3 | 28.1 | 28.4 |
| | | | 4H | 23.4 | 24.1 | 23.7 | 24.4 | 24.8 | 27.3 | 28.1 | 27.7 | 28.4 | 28.8 |
| | | | 6H | 23.3 | 24.0 | 23.7 | 24.3 | 24.7 | 27.5 | 28.2 | 27.9 | 28.5 | 28.9 |
| 8H | 12H | | 23.3 | 23.9 | 23.7 | 24.3 | 24.7 | 27.5 | 28.1 | 28.0 | 28.5 | 28.9 | |
| | | 23.3 | 23.8 | 23.7 | 24.2 | 24.6 | 27.5 | 28.0 | 28.0 | 28.4 | 28.9 | | |
| | | 4H | 23.4 | 24.0 | 23.8 | 24.4 | 24.8 | 27.2 | 27.8 | 27.6 | 28.2 | 28.6 | |
| | | | 6H | 23.4 | 23.8 | 23.8 | 24.3 | 24.7 | 27.4 | 27.9 | 27.9 | 28.3 | 28.8 |
| | | | 8H | 23.3 | 23.8 | 23.8 | 24.2 | 24.7 | 27.4 | 27.9 | 27.9 | 28.3 | 28.8 |
| 12H | 23.3 | | 23.7 | 23.8 | 24.1 | 24.6 | 27.4 | 27.8 | 27.9 | 28.2 | 28.7 | | |
| | 4H | | 23.4 | 23.9 | 23.8 | 24.3 | 24.7 | 27.2 | 27.7 | 27.6 | 28.1 | 28.5 | |
| | | 6H | 23.3 | 23.7 | 23.8 | 24.2 | 24.7 | 27.4 | 27.8 | 27.9 | 28.3 | 28.7 | |
| 8H | | 23.3 | 23.7 | 23.8 | 24.1 | 24.6 | 27.4 | 27.8 | 27.9 | 28.2 | 28.7 | | |
| Variation of the observer position for the luminaire distances S | | | | | | | | | | | | | |
| S = 1.0H S = 1.5H S = 2.0H | | +0.9 / -1.2 +2.2 / -8.3 +3.4 / -9.8 | | | | | +0.1 / -0.1 +0.4 / -0.9 +0.8 / -1.0 | | | | | | |
| Standard table | | BK01 | | | | | BK03 | | | | | | |
| Correction summand | | 4.9 | | | | | 9.3 | | | | | | |
| Corrected glare indices referring to 1395lm Total luminous flux | | | | | | | | | | | | | |

The UGR values are calculated in acc. with CIE Publ. 117. Spacing-to-Height-Ratio = 0.25